


# LP1004SS, LP1504SS, LP2004SS, LP2504SS


## FITTING GUIDE



LP1004SS



LP1504SS



LP2004SS



LP2504SS



### CONTENTS

- LP1004SS, LP1504SS, LP2004SS or LP2504SS fire + smoke seal

### TOOLS REQUIRED

- Router
- Suitable router bit
- Hacksaw/secateurs

For more information please call:

**+9714 883 7206**

### NOTE

The SS fire + smoke seal requires a 3mm gap size for seals with 4mm brush, and a 5mm gap size for seals with 6mm brush, with a 1mm tolerance.

We recommend that, in line with good joinery practice, the edges of door leaves are given a 1° leading edge and chamfered on both edges.

### STEP 1

Before fitting the door frame to the opening, rout all grooves to the back of the frame and head.

### ROUT SIZES

LP1004SS: 10 x 4mm  
 LP1504SS: 15 x 4mm  
 LP2004SS: 20 x 4mm  
 LP2504SS: 25 x 4mm

### STEP 2

Repeat the same operation for the inside of frame and doors where applicable.

### NOTE

All grooves should be of suitable width and depth such that the seals do not stand proud of their surroundings.

### STEP 3

Make sure grooves are free from dust and grease. Lorient does not recommend oil or solvent based paint/primers.

### STEP 4

Measure and cut all seals to length using a hacksaw/secateurs. Remove self-adhesive backing and butt joint fit all seals to inside and outside of door frame or door, and meeting stiles of pairs of doors where applicable. Pressure must be applied to activate adhesive backing properties.

### NOTE

Pinning of seals is not recommended.

### IMPORTANT

Application should be at a temperature **NO LESS than 10°C**. Once installed it may be painted over. **Do not paint the flexible elements of combined acoustic, smoke and fire seals. Freshly painted doorsets should be left open until the paint is fully dry and cured before fitting with combined fire and smoke seals. Some paint or lacquers will affect adhesion.**

### HANDLING + STORAGE

No special precautions are required when handling Lorient acoustic, smoke and fire seals, but they should always be treated with care and not bent or twisted. Safety data sheets are available on request.

The products do not fall within the scope of COSHH regulations. Lorient intumescent seals should be stored flat in a clean, dry, dust-free area away from heat and at a storage temperature of between 5°C and 40°C.



### NOTE

Recommendations as to methods, use of materials and construction details are based on the experience and knowledge of Lorient and are given in good faith as a general guide and service to designers, contractors and manufacturers.

Lorient reserves the right to make alterations or delete any installation detail without prior notice.